



LEAD IN DRINKING WATER FIRST ROUND REPORT ROCKAWAY BOROUGH SCHOOL DISTRICT

PERFORMED FOR:

ROCKAWAY BOROUGH SCHOOL DISTRICT
103 EAST MAIN STREET
ROCKAWAY, NJ 07886

PERFORMED BY:

WESTCHESTER ENVIRONMENTAL LLC
307 N WALNUT STREET
WEST CHESTER, PA 19380

MAY 2017



May 2, 2017

Chris Kelly
Rockaway Borough School District
103 East Main Street
Rockaway, NJ 07866

Re: LEAD IN DRINKING WATER REPORT-FIRST ROUND

Dear Mr. Kelly,

Please find enclosed the report for the Lead in Drinking Water sampling conducted for the Rockaway Borough School District.

If you have any questions, please contact me at 484-894-4841 or email me at pfmccaa@WestChesterEnvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in blue ink that reads 'Paul F. McCaa'.

Paul F. McCaa
Senior Environmental Specialist

Enclosure



TABLE OF CONTENTS

ROCKAWAY BOROUGH SCHOOL DISTRICT

1.0	INTRODUCTION.....	1
2.0	SUMMARY OF FINDINGS.....	2
3.0	SAMPLING AND ANALYSES.....	8
4.0	DISCUSSION & RECOMMENDATIONS.....	9
5.0	DISCLAIMER.....	10

Appendix I – Water Sampling Chain-of-Custody & Laboratory Reports



1.0 INTRODUCTION

Westchester Environmental, LLC was contracted by Chris Kelly to conduct Drinking Water Sampling for Lead at the Rockaway Borough Schools.

The water sampling was performed on April 8 and 14, 2017 by Noel Abraham of Westchester Environmental, LLC.

The purpose of the assessment was to collect water samples at predetermined locations in the facilities and have them analyzed for lead levels.

All samples were analyzed by Suburban Testing Labs located at 1037 MacArthur Rd, Reading, PA 19605, a New Jersey certified Lead in Drinking Water testing facility.

-END OF SECTION-

2.0 SUMMARY OF FINDINGS

First draw & flush water samples were collected and submitted for lead analysis. The tables below show the concentration of lead in ppb (parts per billion or microgram per liter) at each sampled location.

Table 1 Lincoln Elementary School

Sample Number	Location	Action Level	Result	Lead Hazard
		ppb	ppb	YES/NO
7042910-01	Field Blank	15.5	<1.00	NA
7042910-02	B-6-S	15.5	<1.00	NO
7042910-03	B-7-S	15.5	35.4	YES
7042910-04	B-4-1-S	15.5	15.8	YES
7042910-05	B-4-2-S	15.5	3.15	NO
7042910-06	Kitchen 1-FP	15.5	10.3	NO
7042910-07	Kitchen 2-FP	15.5	2.76	NO
7042910-08	B-2-S	15.5	13.4	NO
7042910-09	O/S B2-WC	15.5	1.64	NO
7042910-10	O/S 109-WC	15.5	3.28	NO
7042910-11	CR109-S	15.5	10.7	NO
7042910-12	CR109-DW	15.5	9.12	NO
7042910-13	CR110-1-S	15.5	36.6	YES
7042910-14	CR110-2-S	15.5	8.84	NO
7042910-15	CR110-DW	15.5	19.3	YES
7042910-16	Principal's Office-S	15.5	46.1	YES
7042910-17	O/S 104-WC	15.5	3.5	NO
7042910-18	Girls Rm-1-S	15.5	5.13	NO

Sample Number	Location	Action Level	Result	Lead Hazard
		ppb	ppb	YES/NO
7042910-19	Boy's Rm-1-S	15.5	19.1	YES
7042910-20	Boy's Rm-2-S	15.5	11.8	NO
7042910-21	CR 101-S	15.5	5.67	NO
7042910-22	CR 101-DW	15.5	3.73	NO
7042910-23	O/S 211-S	15.5	3.85	NO
7042910-24	Nurse's Office-NS	15.5	14.8	NO
7042910-25	Nurse's Office-NS	15.5	1.79	NO
7042910-26	Hall o/s 203-WC	15.5	1.52	NO
7042910-27	Girl's Rm-4-S	15.5	19.5	YES
7042910-28	Girl's Rm-5-S	15.5	17.9	YES
7042910-29	Boy's Rm-3-S	15.5	12.1	NO
7042910-30	Boy's Rm-4-S	15.5	4.07	NO
7042910-31	Boy's Rm-5-S	15.5	91.6	YES
7042910-32	Laboratory Control Sample	15.5	15.1	NA
7042910-33	Laboratory Control Sample Duplicate	15.5	15	NA

Samples highlighted in **yellow** were above the EPA action level of 15.5 parts per billion (ppb) or 0.015 milligrams per liter (mg/l).

Table 2 Thomas Jefferson Middle School

Sample Number	Location Code	Action Level	Result	Lead Hazard
		ppb	ppb	YES/NO
7042910-01	RJMS--- Field Blank	15.5	<1.00	NA
7042910-02	RJMS-1FL-POE- Conf. Rm	15.5	<1.00	NO
7042910-03	RJMS-1FL-S-Principals Office 1	15.5	27.6	YES
7042910-04	RJMS-1FL-DW-O/S Main Office	15.5	3.72	NO
7042910-05	RJMS-1FL-S-Lav @ Main Entry	15.5	11.4	NO
7042910-06	RJMS-1FL-S-Prep Rm	15.5	485	YES
7042910-07	RJMS-1FL-WC-hall o/s Computer Lab	15.5	4.96	NO
7042910-08	RJMS-1FL-S-Home EC Lab 1	15.5	20.7	YES
7042910-09	RJMS-1FL-S-Home EC Lab 3	15.5	65.2	YES
7042910-10	RJMS-1FL-S-Prep Rm-2	15.5	26.6	YES
7042910-11	RJMS-1FL-S-Science Rm	15.5	11.3	NO
7042910-12	RJMS-1FL-S-Science Rm 2	15.5	16	YES
7042910-13	RJMS-1FL-S-Science Rm 3	15.5	13.5	NO
7042910-14	RJMS-1FL-S-Science Rm 4	15.5	14.4	NO
7042910-15	RJMS-1FL-S-Science Rm 5	15.5	18.2	YES
7042910-16	RJMS-1FL-S-Science Rm 6	15.5	13.8	NO
7042910-17	RJMS-1FL-S-Science Rm 7	15.5	16.1	YES
7042910-18	RJMS-1FL-S-Science Rm 8	15.5	12.7	NO
7042910-19	RJMS-1FL-S- Girls Locker Rm	15.5	16.7	YES
7042910-20	RJMS-1FL-S-Boys Locker Rm	15.5	15.5	YES

Sample Number	Location Code	Action Level	Result	Lead Hazard
		ppb	ppb	YES/NO
7042910-21	RJMS-1FL-S-Art Rm 1	15.5	24.5	YES
7042910-22	RJMS-1FL-S-Art Rm 2	15.5	6.79	NO
7042910-23	RJMS-1FL-S-Art Rm 3	15.5	3.77	NO
7042910-24	RJMS-1FL-S-Art Rm 4	15.5	11.7	NO
7042910-25	RJMS-1FL-S-Art Rm 5	15.5	11.1	NO
7042910-26	RJMS-1FL-S-Art Rm 6	15.5	2.34	NO
7042910-27	RJMS-1FL-DW-Hall o/s Music Rm	15.5	17.5	YES
7042910-28	RJMS-1FL-WC- Cafeteria 1	15.5	8.52	NO
7042910-29	RJMS-1FL-S-Kitchen 1	15.5	25.8	YES
7042910-30	RJMS-1FL-S-Kitchen 2	15.5	34.3	YES
7042910-31	RJMS-1FL-S-Kitchen 3	15.5	6.39	NO
7042910-32	RJMS-2FL-FS-Faculty Rm	15.5	9.84	NO
7042910-33	RJMS-3FL-NS-Nurse's Office	15.5	11.4	NO
7042910-34	RJMS-2FL-S-CR 101	15.5	16.6	YES
7042910-35	RJMS-1FL-DW-CR 101	15.5	38.1	YES
7042910-36	RJMS-1 FL-S-CR 102	15.5	23.9	YES
7042910-37	RJMS-1FL-S-Library	15.5	32	YES
7042910-38	RJMS-1FL-DW-Library	15.5	37	YES
7042910-39	RJMS-1FL-S-Girls Rm 1	15.5	26.6	YES
7042910-40	RJMS-1FL-S-Girls Rm 2	15.5	7.66	NO
7042910-41	RJMS-1FL-S-Girls Rm 3	15.5	5.1	NO
7042910-42	RJMS-1FL-WC-O/S 118	15.5	<1.00	NO
7042910-43	RJMS-1FL-S- Boys Rm 2	15.5	12.6	NO
7042910-44	RJMS-1FL-S- Boys Rm 3	15.5	8.82	NO
7042910-45	RJMS-1FL-S-CR 105	15.5	63	YES

Sample Number	Location Code	Action Level	Result	Lead Hazard
		ppb	ppb	YES/NO
7042910-46	RJMS-1FL-DW-CR 105	15.5	143	YES
7042910-47	RJMS-1FL-S-CR 117	15.5	86.6	YES
7042910-48	RJMS-1FL-DW-CR 117	15.5	13.4	NO
7042910-49	RJMS-1FL-S-CR-106	15.5	396	YES
7042910-50	RJMS-1FL-DW-CR-106	15.5	158	YES
7042910-51	RJMS-1FL-S-CR 116	15.5	25.5	YES
7042910-52	RJMS-1FL-DW-CR 116	15.5	30.8	YES
7042910-53	RJMS-1FL-S-CR 107	15.5	81.1	YES
7042910-54	RJMS-1FL-DW-CR 107	15.5	47.4	YES
7042910-55	RJMS-1FL-S-CR 108	15.5	96.5	YES
7042910-56	RJMS-1FL-DW-CR 108	15.5	89.5	YES
7042910-57	RJMS-1FL-S-CR 115	15.5	36.8	YES
7042910-58	RJMS-1FL-S-CR 114	15.5	51.3	YES
7042910-59	RJMS-1FL-DW-CR 114	15.5	13.6	NO
7042910-60	RJMS-1FL-S-CR 109	15.5	107	YES
7042910-61	RJMS-1-FL-S-CR 113	15.5	175	YES
7042910-62	RJMS-1FL-S-CR 110	15.5	86.9	YES
7042910-63	RJMS-1FL-DW-CR 110	15.5	57.9	YES
7042910-64	RJMS-1FL-DW-CR 112	15.5	171	YES
7042910-65	RJMS-1FL-S-CR 112	15.5	97.5	YES
7042910-66	RJMS-1FL-S-CR 111	15.5	42.6	YES
7042910-67	RJMS-1FL-WC-O/S 111	15.5	6.83	NO
7042910-68	RJMS-1FL-S-Boys Rm 4	15.5	6.57	NO
7042910-69	RJMS-1FL-S-Boys Rm 5	15.5	4.42	NO
7042910-70	RJMS-1FL-S-Boys Rm 6	15.5	2.87	NO

Sample Number	Location Code	Action Level	Result	Lead Hazard
		ppb	ppb	YES/NO
7042910-71	RJMS-1FL-S-Girls Rm 4	15.5	3.56	NO
7042910-72	RJMS-1FL-S-Girls Rm 5	15.5	2.21	NO
7042910-73	RJMS-1FL-S-Girls Rm 6	15.5	5.04	NO
7042910-74	RJMS-1FL-DW-CR 136W	15.5	10.4	NO
7042910-75	RJMS-1FL-S-CR 136W	15.5	6.29	NO
7042910-76	RJMS-1FL-DW-CR 137W	15.5	1.94	NO
7042910-77	RJMS-1FL-S-CR 137W	15.5	<1.00	NO
7042910-78	RJMS-1FL-DW-CR 138W	15.5	3.19	NO
7042910-79	RJMS-1FL-S-CR 138W	15.5	3.47	NO
7042910-80	Laboratory Control Sample	NA	14.8	NA
7042910-81-RE1	Laboratory Control Sample Duplicate	NA	14.1	NA

Samples highlighted in yellow were above the EPA action level of 15.5 parts per billion (ppb) or 0.015 milligrams per liter (mg/l)).

-END OF SECTION-

3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Twenty-nine 250 ml. first draw samples and one 250 ml. flush sample (Point of Entry) were collected from the Lincoln Elementary School at locations pre-determined by school personnel, along with one field blank for Quality Control Purposes.

Seventy-seven 250 ml. first draw samples and one 250 ml. flush sample (Point of Entry) were collected from the Thomas Jefferson Middle School at locations pre-determined by school personnel, along with one field blank for Quality Control Purposes.

All samples were labeled with a unique identification number and transported to the Suburban Laboratory for analysis for lead in drinking water using EPA Method 200.8.

-END OF SECTION-

4.0 DISCUSSION & RECOMMENDATIONS

According to the US EPA, lead enters drinking water primarily through plumbing materials.

For further information on guidance protocols and Action Levels that were followed please refer to:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Based on a laboratory analysis after the initial round of sampling, the following are recommended:

Immediate / Short Term Action Required:

1. Immediately discontinue using water at locations exceeding the NJDEP 15.5 ppb Action Level.
2. Assign a person of contact and immediately communicate with interested parties (Civic Groups, the Media, Parents, etc.) regarding the testing. Follow the protocols outlined in N.J.A.C. 6A:26 for notification.
3. The next step in the NJDEP Regulations requires the analysis of the collected flush sample at those sample points reported to contain lead in concentrations above the 15.5 ppb action level.

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location and are reflective of the conditions at that time of collection. Since conditions may vary over time we recommend periodic sampling to monitor the lead concentrations at the facilities.

It is important to note that the Lead Hazard Assessment was a snap shot of the conditions existing at the time of the assessment and conditions may vary with time.

-END OF SECTION-



5.0 DISCLAIMER

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment only.

Westchester Environmental LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for, and is confidential to, the above noted client. Westchester Environmental LLC assumes no liability with regards to the use of this information or decisions, which are made regarding the subject property. The user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in blue ink that reads 'Paulk F. McCaa'. The signature is written in a cursive style and is positioned above the printed name and title.

Paulk F. McCaa
Senior Environmental Specialist

-END OF REPORT-

APPENDIX I

LEAD IN DRINKING WATER SAMPLING CHAINS-OF-CUSTODY & LAB REPORTS



Results Report

Order ID: 7042910

Westchester Environmental
307 North Walnut Street
West Chester, PA 19380

Project: Rockaway Borough, NJ SD - Lincoln ES
37 Keller Avenue
Rockaway, NJ 07866

Attn: Westchester Environmental

Regulatory ID:

Sample Number: 7042910-01
Collector: NPA

Site: Field Blank
Collect Date: 04/08/2017 10:50 am

Sample ID: RLES-LFL-- Field Blank
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:48 RPV

Sample Number: 7042910-02
Collector: NPA

Site: B-6
Collect Date: 04/08/2017 10:53 am

Sample ID: RLES-LFL-POE-B-6
Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 21:56 RPV

Sample Number: 7042910-03
Collector: NPA

Site: B-7
Collect Date: 04/08/2017 10:54 am

Sample ID: RLES-LFL-S-B-7
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 35.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:02 RPV

Sample Number: 7042910-04
Collector: NPA

Site: B-4-1
Collect Date: 04/08/2017 10:55 am

Sample ID: RLES-LFL-S-B-4 -1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:04 RPV

Sample Number: 7042910-05
Collector: NPA

Site: B-4-2
Collect Date: 04/08/2017 10:56 am

Sample ID: RLES-LFL-S-B-4 -2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.15 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:06 RPV

Report Generated On: 04/25/2017 4:21 pm
STL_Results Revision #1.6

7042910
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042910-06
Collector: NPA

Site: Kitchen 1
Collect Date: 04/08/2017 10:57 am

Sample ID: RLES-LFL-FP-Kitchen 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 10.3 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:08 RPV

Sample Number: 7042910-07
Collector: NPA

Site: Kitchen 2
Collect Date: 04/08/2017 10:58 am

Sample ID: RLES-LFL-FP-Kitchen 2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.76 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:10 RPV

Sample Number: 7042910-08
Collector: NPA

Site: B-2
Collect Date: 04/08/2017 10:59 am

Sample ID: RLES-LFL-S-B-2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:16 RPV

Sample Number: 7042910-09
Collector: NPA

Site: O/S B2
Collect Date: 04/08/2017 11:00 am

Sample ID: RLES-LFL-WC-O/S B2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.64 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:17 RPV

Sample Number: 7042910-10
Collector: NPA

Site: O/S 109
Collect Date: 04/08/2017 11:01 am

Sample ID: RLES-LFL-WC-O/S 109
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.28 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:19 RPV

Sample Number: 7042910-11
Collector: NPA

Site: CR109
Collect Date: 04/08/2017 11:02 am

Sample ID: RLES-MFL-S-CR109
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 10.7 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:21 RPV

Report Generated On: 04/25/2017 4:21 pm 7042910
STL_Results Revision #1.6 Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042910-12
Collector: NPA

Site: CR109
Collect Date: 04/08/2017 11:03 am

Sample ID: RLES-MFL-DW-CR109
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 9.12 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:23 RPV

Sample Number: 7042910-13
Collector: NPA

Site: CR110-1
Collect Date: 04/08/2017 11:04 am

Sample ID: RLES-MFL-S-CR110 -1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 36.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:27 RPV

Sample Number: 7042910-14
Collector: NPA

Site: CR110-2
Collect Date: 04/08/2017 11:05 am

Sample ID: RLES-MFL-S-CR110 -2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 8.84 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:29 RPV

Sample Number: 7042910-15
Collector: NPA

Site: CR110
Collect Date: 04/08/2017 11:06 am

Sample ID: RLES-MFL-DW-CR110
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 19.3 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:31 RPV

Sample Number: 7042910-16
Collector: NPA

Site: Principal's Office
Collect Date: 04/08/2017 11:07 am

Sample ID: RLES-MFL-S-Principal's Office
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 46.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:33 RPV

Sample Number: 7042910-17
Collector: NPA

Site: O/S 104
Collect Date: 04/08/2017 11:08 am

Sample ID: RLES-MFL-WC-O/S 104
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.50 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:39 RPV

Report Generated On: 04/25/2017 4:21 pm 7042910
STL_Results Revision #1.6 Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042910-18
Collector: NPA

Site: Girls Rm-1
Collect Date: 04/08/2017 11:09 am

Sample ID: RLES-MFL-S-Girls Rm -1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.13 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:41 RPV

Sample Number: 7042910-19
Collector: NPA

Site: Boy's Rm-1
Collect Date: 04/08/2017 11:11 am

Sample ID: RLES-MFL-S-Boy's Rm -1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 19.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:43 RPV

Sample Number: 7042910-20
Collector: NPA

Site: Boy's Rm-2
Collect Date: 04/08/2017 11:12 am

Sample ID: RLES-MFL-S-Boy's Rm -2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:45 RPV

Sample Number: 7042910-21
Collector: NPA

Site: CR 101
Collect Date: 04/08/2017 11:13 am

Sample ID: RLES-MFL-S-CR 101
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.67 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:47 RPV

Sample Number: 7042910-22
Collector: NPA

Site: CR 101
Collect Date: 04/08/2017 11:14 am

Sample ID: RLES-MFL-DW-CR 101
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.73 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 22:53 RPV

Sample Number: 7042910-23
Collector: NPA

Site: O/S 211
Collect Date: 04/08/2017 11:15 am

Sample ID: RLES-2FL-O/S 211
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.85 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:02 RPV

Report Generated On: 04/25/2017 4:21 pm 7042910
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7042910-24 Site: Nurse's Office Sample ID: RLES-2FL-NS-Nurse's Office
Collector: NPA Collect Date: 04/08/2017 11:16 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:04 RPV

Sample Number: 7042910-25 Site: Nurse's Office Sample ID: RLES-2FL-S-Nurse's Office
Collector: NPA Collect Date: 04/08/2017 11:17 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.79 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:06 RPV

Sample Number: 7042910-26 Site: Hall o/s 203 Sample ID: RLES-2FL-WC-Hall o/s 203
Collector: NPA Collect Date: 04/08/2017 11:18 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.52 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:08 RPV

Sample Number: 7042910-27 Site: Girl's Rm-4 Sample ID: RLES-2FL-S-Girl's Rm -4
Collector: NPA Collect Date: 04/08/2017 11:19 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 19.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:10 RPV

Sample Number: 7042910-28 Site: Girl's Rm-5 Sample ID: RLES-2FL-S-Girl's Rm -5
Collector: NPA Collect Date: 04/08/2017 11:20 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 17.9 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:12 RPV

Sample Number: 7042910-29 Site: Boy's Rm-3 Sample ID: RLES-2FL-S-Boy's Rm -3
Collector: NPA Collect Date: 04/08/2017 11:21 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 12.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:14 RPV

Report Generated On: 04/25/2017 4:21 pm 7042910
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 7042910-30
Collector: NPA

Site: Boy's Rm-4
Collect Date: 04/08/2017 11:22 am

Sample ID: RLES-2FL-S-Boy's Rm -4
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.07 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:16 RPV

Sample Number: 7042910-31
Collector: NPA

Site: Boy's Rm-5
Collect Date: 04/08/2017 11:23 am

Sample ID: RLES-2FL-S-Boy's Rm -5
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 91.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:18 RPV

Sample Number: 7042910-32
Collector:

Site: Laboratory Control Sample
Collect Date: 04/11/2017 12:00 am

Sample ID:
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:20 RPV

Sample Number: 7042910-33
Collector:

Site: Laboratory Control Sample Duplicate
Collect Date: 04/11/2017 12:00 am

Sample ID:
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.0 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 23:26 RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Alana Kopicz
Project Manager

Alana M. Kopicz

Report Generated On: 04/25/2017 4:21 pm 7042910
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



7042910
Alana Kopicz



SUBURBAN
TESTING LABS

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Lincoln Elementary		
	West Chester, PA 19380	Email:	nabraham@westchesterenv ironmental.com		37 Keller Ave, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
	Field Blank	04/08/17	10:50 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL--Field Blank
Flush	B-6	04/08/17	10:53 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-POE-B-6
First	B-7	04/08/17	10:54 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-S-B-7
First	B-4 -1	04/08/17	10:55 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-S-B-4 -1
First	B-4 -2	04/08/17	10:56 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-S-B-4 -2
First	Kitchen 1	04/08/17	10:57 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-FP-Kitchen 1
First	Kitchen 2	04/08/17	10:58 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-FP-Kitchen 2
First	B-2	04/08/17	10:59 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-S-B-2
First	O/S B2	04/08/17	11:00 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-WC-O/S B2
First	O/S 109	04/08/17	11:01 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-WC-O/S 109

PH C2
↓

Relinquished by:

[Signature]

Date: 4/11/17
Time: 09:00

Received By:

Cathy Flynn *Qcoolers*

Date: 4/11/17 Temp °C: 23.6
Time: 12:00 Acceptable Y / N

Relinquished by:

Cathy Flynn


Date: 4/11/17 Temp °C: 23.8
Time: 15:20 Acceptable Y / N

Received in Lab By:

Ross McLean

Date: 4/11/17 Temp °C:
Time: 15:20 Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance)	Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH	☐ Fax
All containers intact ☒ Y ☐ N	SWDA = Safe Drinking Water Act Potable Sample	A = Ascorbic H = HNO ₃ S = OH = Q = Other	☐ Email
Tests within holding times ☒ Y ☐ N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	☐ Other
40 ml. VOA vials free of headspace? ☒ Y ☐ N		NA = None Required	☐ Return a copy of



7042910
Alana Kopicz



SUBURBAN
TESTING LABS

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Lincoln Elementary		
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		37 Keller Ave, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	CR109	04/08/17	11:02 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-CR109
First	CR109	04/08/17	11:03 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-DW-CR109
First	CR110 -1	04/08/17	11:04 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-CR110 -1
First	CR110 -2	04/08/17	11:05 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-CR110 -2
First	CR110	04/08/17	11:06 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-DW-CR110
First	Principal's Office	04/08/17	11:07 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-Principal's Office
First	O/S 104	04/08/17	11:08 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-WC-O/S 104
First	Girls Rm -1	04/08/17	11:09 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-Girls Rm -1
First	Boy's Rm -1	04/08/17	11:11 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-Boy's Rm -1
First	Boy's Rm -2	04/08/17	11:12 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-Boy's Rm -2

ptfcb
↓

Relinquished by:

Nailete

Received By:

Catelyn Flynn

Relinquished by:

Catelyn Flynn

Received in Lab By:

Ron McLean

Date:

4/11/17

Time: 09:00

Date:

4/11/17 Temp °C: 23.6

Time:

12:00 Acceptable Y/N

Date:

4/11/17 Temp °C: 23.8

Time:

15:20 Acceptable Y/N

Date:

4/11/17 Temp °C:

Time:

15:20 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass	☐ Fax
All containers intact ☒ Y ☐ N	PW = Potable Water (not for SWDA compliance)	O = Other	☐ Email
Tests within holding times ☒ Y ☐ N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	☐ Other
40 ml. VOA vials free of headspace? ☒ Y ☐ N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	H = Sodium Thiosulphate A = Ascorbic Acid C = HCl H ₂ SO ₄ NaOH NA = None Required	☐ Return a copy of
	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		



7042910
Alana Kopicz



SUBURBAN
TESTING LABS

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Lincoln Elementary		
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		37 Keller Ave, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
First	CR 101	04/08/17	11:13 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-CR 101
First	CR 101	04/08/17	11:14 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-DW-CR 101
First	O/S 211	04/08/17	11:15 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-WC-O/S 211
First	Nurse's Office	04/08/17	11:16 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-NS-Nurse's Office
First	Nurse's Office	04/08/17	11:17 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Nurse's Office
First	Hall o/s 203	04/08/17	11:18 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-WC-Hall o/s 203
First	Girl's Rm -4	04/08/17	11:19 AM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Girl's Rm -4
First	Girl's Rm -5	04/08/17	11:20 AM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Girl's Rm -5
First	Boy's Rm -3	04/08/17	11:21 AM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Boy's Rm -3
First	Boy's Rm -4	04/08/17	11:22 AM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Boy's Rm -4

Relinquished by:

[Signature]

Received By:

[Signature]

Relinquished by:

[Signature] ⑩

Received in Lab By:

[Signature]

Date: 4/11/17

Time: 09:00

Date: 4/11/17 Temp °C: 23.6

Time: 12:00 Acceptable Y/N

Date: 4/11/17 Temp °C: 23.8

Time: 15:20 Acceptable Y/N

Date: 4/11/17 Temp °C:

Time: 15:20 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic	☐ SWDA
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass	☐ Reportin
All containers intact ☒ Y ☐ N	PW = Potable Water (not for SWDA compliance)	O = Other	☐ Fax
Tests within holding times ☒ Y ☐ N	SWDA = Safe Drinking Water Act	Preservative Key	☐ Email
40 ml. VOA vials free of headspace? ☒ Y ☐ N	Potable Sample	H = Sodium	☐ Other
	Sample Type Key : SWDA Sample Type	Thiosulphate Acid	☐ Return a copy of
	G = Grab	A = Ascorbic	
	8 HC = 8 Hour	H = HNO3	
	Composite	C = HCl	
	24 HC = 24 Hour	H2SO4	
	Composite	NaOH	
	Residence	OH =	
		NA = None Required	



7042910
Alana Kopicz



SUBURBAN
TESTING LABS

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST – Fax: 610-375-4090 – suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Lincoln Elementary		
	West Chester, PA 19380	Email:	nabraham@westchesterenv ironmental.com		37 Keller Ave, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
First	Boy's Rm -5	04/08/17	11:23 AM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Boy's Rm -5

Relinquished by:

[Signature]

Received By:

[Signature]

Relinquished by:

[Signature]

Received in Lab By:

[Signature]

Date:

4/11/17

Time:

08:00

Date:

4/11/17

Time:

12:00

Date:

4/11

Time:

15:20

Date:

4/11/17

Time:

15:20

Temp °C:

23.6

Temp °C:

23.8

Acceptable

Y/N

Acceptable

Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance)	G = Glass	☐ Fax
All containers intact ☒ Y ☐ N	SWDA = Safe Drinking Water Act Potable Sample	O = Other	☐ Email
Tests within holding times ☒ Y ☐ N	40 ml. VOA vials free of headspace? ☐ Y ☐ N	Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH A = Ascorbic H = HNO ₃ S = OH = O = Other NA = None Required	☐ Other ☐ Return a copy of
	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		



Results Report

Order ID: 7042907

Westchester Environmental
307 North Walnut Street
West Chester, PA 19380

Project: Rockaway Borough, NJ SD - Thomas Jefferson MS
95 E. Main Street
Rockaway, NJ 07866

Attn: Westchester Environmental

Regulatory ID:

Sample Number: 7042907-01
Collector: NPA

Site: Field Blank
Collect Date: 04/08/2017 9:25 am

Sample ID: RJMS--- Field Blank
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:29 RPV

Sample Number: 7042907-02
Collector: NPA

Site: Conf. Rm Br
Collect Date: 04/08/2017 9:30 am

Sample ID: RJMS-1FL-POE- Conf. Rm Br
Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:35 RPV

Sample Number: 7042907-03
Collector: NPA

Site: Principals Office 1
Collect Date: 04/08/2017 9:31 am

Sample ID: RJMS-1FL-S-Principals Office 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 27.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:37 RPV

Sample Number: 7042907-04
Collector: NPA

Site: O/S Main Office
Collect Date: 04/08/2017 9:32 am

Sample ID: RJMS-1FL-DW-O/S Main Office
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.72 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:39 RPV

Sample Number: 7042907-05
Collector: NPA

Site: Lav @ Main Entry
Collect Date: 04/08/2017 9:33 am

Sample ID: RJMS-1FL-S-Lav @ Main Entry
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:41 RPV

Report Generated On: 05/01/2017 2:45 pm
STL_Results Revision #1.6

7042907
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042907-06
Collector: NPA

Site: Prep Rm
Collect Date: 04/08/2017 9:34 am

Sample ID: RJMS-1FL-S-Prep Rm
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 485 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/14/17 18:02 RPV

Sample Number: 7042907-07
Collector: NPA

Site: Hall o/s Computer Lab
Collect Date: 04/08/2017 9:35 am

Sample ID: RJMS-1FL-WC-hall o/s Computer L
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.96 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:43 RPV

Sample Number: 7042907-08
Collector: NPA

Site: Home EC Lab 1
Collect Date: 04/08/2017 9:35 am

Sample ID: RJMS-1FL-S-Home EC Lab 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 20.7 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:45 RPV

Sample Number: 7042907-09
Collector: NPA

Site: Home EC Lab 3
Collect Date: 04/08/2017 9:36 am

Sample ID: RJMS-1FL-S-Home EC Lab 3
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 65.2 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 16:51 RPV

Sample Number: 7042907-10
Collector: NPA

Site: Prep Rm-2
Collect Date: 04/08/2017 9:37 am

Sample ID: RJMS-1FL-S-Prep Rm-2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 26.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:00 RPV

Sample Number: 7042907-11
Collector: NPA

Site: Science Rm 1
Collect Date: 04/08/2017 9:38 am

Sample ID: RJMS-1FL-S-Science Rm 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.3 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:02 RPV

Report Generated On: 05/01/2017 2:45 pm
STL_Results Revision #1.6

7042907
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042907-12
Collector: NPA

Site: Science Rm 2
Collect Date: 04/08/2017 9:39 am

Sample ID: RJMS-1FL-S-Science Rm 2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 16.0 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:04 RPV

Sample Number: 7042907-13
Collector: NPA

Site: Science Rm 3
Collect Date: 04/08/2017 9:40 am

Sample ID: RJMS-1FL-S-Science Rm 3
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:06 RPV

Sample Number: 7042907-14
Collector: NPA

Site: Science Rm 4
Collect Date: 04/08/2017 9:41 am

Sample ID: RJMS-1FL-S-Science Rm 4
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:08 RPV

Sample Number: 7042907-15
Collector: NPA

Site: Science Rm 5
Collect Date: 04/08/2017 9:42 am

Sample ID: RJMS-1FL-S-Science Rm 5
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 18.2 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:10 RPV

Sample Number: 7042907-16
Collector: NPA

Site: Science Rm 6
Collect Date: 04/08/2017 9:43 am

Sample ID: RJMS-1FL-S-Science Rm 6
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:12 RPV

Sample Number: 7042907-17
Collector: NPA

Site: Science Rm 7
Collect Date: 04/08/2017 9:44 am

Sample ID: RJMS-1FL-S-Science Rm 7
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 16.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:14 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7042907-18
Collector: NPA

Site: Science Rm 8
Collect Date: 04/08/2017 9:45 am

Sample ID: RJMS-1FL-S-Science Rm 8
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 12.7 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:16 RPV

Sample Number: 7042907-19
Collector: NPA

Site: Girls Locker Rm
Collect Date: 04/08/2017 9:46 am

Sample ID: RJMS-1FL-S- Girls Locker Rm
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 16.7 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:22 RPV

Sample Number: 7042907-20
Collector: NPA

Site: Boys Locker Rm
Collect Date: 04/08/2017 9:47 am

Sample ID: RJMS-1FL-S-Boys Locker Rm
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:25 RPV

Sample Number: 7042907-21
Collector: NPA

Site: Art Rm 1
Collect Date: 04/08/2017 9:48 am

Sample ID: RJMS-1FL-S-Art Rm 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 24.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:27 RPV

Sample Number: 7042907-22
Collector: NPA

Site: Art Rm 2
Collect Date: 04/08/2017 9:49 am

Sample ID: RJMS-1FL-S-Art Rm 2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.79 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:29 RPV

Sample Number: 7042907-23
Collector: NPA

Site: Art Rm 3
Collect Date: 04/08/2017 9:50 am

Sample ID: RJMS-1FL-S-Art Rm 3
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.77 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:31 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 7042907-24
Collector: NPA

Site: Art Rm 4
Collect Date: 04/08/2017 9:51 am

Sample ID: RJMS-1FL-S-Art Rm 4
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.7 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:33 RPV

Sample Number: 7042907-25
Collector: NPA

Site: Art Rm 5
Collect Date: 04/08/2017 9:52 am

Sample ID: RJMS-1FL-S-Art Rm 5
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:35 RPV

Sample Number: 7042907-26
Collector: NPA

Site: Art Rm 6
Collect Date: 04/08/2017 9:53 am

Sample ID: RJMS-1FL-S-Art Rm 6
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.34 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:37 RPV

Sample Number: 7042907-27
Collector: NPA

Site: Hall o/s Music Rm
Collect Date: 04/08/2017 9:54 am

Sample ID: RJMS-1FL-DW-Hall o/s Music Rm
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 17.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:39 RPV

Sample Number: 7042907-28
Collector: NPA

Site: Cafeteria 1
Collect Date: 04/08/2017 9:55 am

Sample ID: RJMS-1FL-WC- Cafeteria 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 8.52 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:49 RPV

Sample Number: 7042907-29
Collector: NPA

Site: Kitchen 1
Collect Date: 04/08/2017 9:56 am

Sample ID: RJMS-1FL-S-Kitchen 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 25.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 17:55 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7042907-30
Collector: NPA

Site: Kitchen 2
Collect Date: 04/08/2017 9:57 am

Sample ID: RJMS-1FL-S-Kitchen 2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 34.3 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:01 RPV

Sample Number: 7042907-31
Collector: NPA

Site: Kitchen 3
Collect Date: 04/08/2017 9:58 am

Sample ID: RJMS-1FL-S-Kitchen 3
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.39 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:03 RPV

Sample Number: 7042907-32
Collector: NPA

Site: Faculty Rm
Collect Date: 04/08/2017 9:59 am

Sample ID: RJMS-2FL-FS-Faculty Rm
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 9.84 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:05 RPV

Sample Number: 7042907-33
Collector: NPA

Site: Nurse's Office
Collect Date: 04/08/2017 10:00 am

Sample ID: RJMS-3FL-NS-Nurse's Office
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:07 RPV

Sample Number: 7042907-34
Collector: NPA

Site: CR 101
Collect Date: 04/08/2017 10:01 am

Sample ID: RJMS-2FL-S-CR 101
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 16.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:12 RPV

Sample Number: 7042907-35
Collector: NPA

Site: CR 101
Collect Date: 04/08/2017 10:02 am

Sample ID: RJMS-1FL-DW-CR 101
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 38.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:14 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7042907-36
Collector: NPA

Site: CR 102
Collect Date: 04/08/2017 10:03 am

Sample ID: RJMS-1 FL-S-CR 102
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 23.9 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:16 RPV

Sample Number: 7042907-37
Collector: NPA

Site: Library
Collect Date: 04/08/2017 10:04 am

Sample ID: RJMS-1FL-S-Library
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 32.0 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:18 RPV

Sample Number: 7042907-38
Collector: NPA

Site: Library
Collect Date: 04/08/2017 10:05 am

Sample ID: RJMS-1FL-DW-Library
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 37.0 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:20 RPV

Sample Number: 7042907-39
Collector: NPA

Site: Girls Rm 1
Collect Date: 04/08/2017 10:06 am

Sample ID: RJMS-1FL-S-Girls Rm 1
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 26.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:22 RPV

Sample Number: 7042907-40
Collector: NPA

Site: Girls Rm 2
Collect Date: 04/08/2017 10:07 am

Sample ID: RJMS-1FL-S-Girls Rm 2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 7.66 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:26 RPV

Sample Number: 7042907-41
Collector: NPA

Site: Girls Rm 3
Collect Date: 04/08/2017 10:08 am

Sample ID: RJMS-1FL-S-Girls Rm 3
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.10 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:28 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042907-42
Collector: NPA

Site: O/S 118
Collect Date: 04/08/2017 10:09 am

Sample ID: RJMS-1FL-WC-O/S 118
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:30 RPV

Sample Number: 7042907-43
Collector: NPA

Site: Boys Rm 2
Collect Date: 04/08/2017 10:10 am

Sample ID: RJMS-1FL-S- Boys Rm 2
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 12.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:36 RPV

Sample Number: 7042907-44
Collector: NPA

Site: Boys Rm 3
Collect Date: 04/08/2017 10:11 am

Sample ID: RJMS-1FL-S- Boys Rm 3
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 8.82 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:38 RPV

Sample Number: 7042907-45
Collector: NPA

Site: CR 105
Collect Date: 04/08/2017 10:12 am

Sample ID: RJMS-1FL-S-CR 105
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 63.0 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:40 RPV

Sample Number: 7042907-46
Collector: NPA

Site: CR 105
Collect Date: 04/08/2017 10:13 am

Sample ID: RJMS-1FL-DW-CR 105
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 143 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:42 RPV

Sample Number: 7042907-47
Collector: NPA

Site: CR 117
Collect Date: 04/08/2017 10:14 am

Sample ID: RJMS-1FL-S-CR 117
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 86.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:44 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042907-48
Collector: NPA

Site: CR 117
Collect Date: 04/08/2017 10:14 am

Sample ID: RJMS-1FL-DW-CR 117
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:46 RPV

Sample Number: 7042907-49
Collector: NPA

Site: CR 106
Collect Date: 04/08/2017 10:15 am

Sample ID: RJMS-1FL-S-CR-106
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 396 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 18:52 RPV

Sample Number: 7042907-50
Collector: NPA

Site: CR 106
Collect Date: 04/08/2017 10:16 am

Sample ID: RJMS-1FL-DW-CR-106
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 158 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:01 RPV

Sample Number: 7042907-51
Collector: NPA

Site: CR 116
Collect Date: 04/08/2017 10:16 am

Sample ID: RJMS-1FL-S-CR 116
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 25.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:03 RPV

Sample Number: 7042907-52
Collector: NPA

Site: CR 116
Collect Date: 04/08/2017 10:17 am

Sample ID: RJMS-1FL-DW-CR 116
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 30.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:05 RPV

Sample Number: 7042907-53
Collector: NPA

Site: CR 107
Collect Date: 04/08/2017 10:18 am

Sample ID: RJMS-1FL-S-CR 107
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 81.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:07 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 7042907-54
Collector: NPA

Site: CR 107
Collect Date: 04/08/2017 10:19 am

Sample ID: RJMS-1FL-DW-CR 107
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 47.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:09 RPV

Sample Number: 7042907-55
Collector: NPA

Site: CR 108
Collect Date: 04/08/2017 10:20 am

Sample ID: RJMS-1FL-S-CR 108
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 96.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:11 RPV

Sample Number: 7042907-56
Collector: NPA

Site: CR 108
Collect Date: 04/08/2017 10:21 am

Sample ID: RJMS-1FL-DW-CR 108
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 89.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:13 RPV

Sample Number: 7042907-57
Collector: NPA

Site: CR 115
Collect Date: 04/08/2017 10:22 am

Sample ID: RJMS-1FL-S-CR 115
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 36.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:15 RPV

Sample Number: 7042907-58
Collector: NPA

Site: CR 114
Collect Date: 04/08/2017 10:23 am

Sample ID: RJMS-1FL-S-CR 114
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 51.3 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:17 RPV

Sample Number: 7042907-59
Collector: NPA

Site: CR 114
Collect Date: 04/08/2017 10:24 am

Sample ID: RJMS-1FL-DW-CR 114
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:28 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 7042907-60
Collector: NPA

Site: CR 109
Collect Date: 04/08/2017 10:24 am

Sample ID: RJMS-1FL-S-CR 109
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 107 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:32 RPV

Sample Number: 7042907-61
Collector: NPA

Site: CR 113
Collect Date: 04/08/2017 10:26 am

Sample ID: RJMS-1-FL-S-CR 113
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 175 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:34 RPV

Sample Number: 7042907-62
Collector: NPA

Site: CR 110
Collect Date: 04/08/2017 10:27 am

Sample ID: RJMS-1FL-S-CR 110
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 86.9 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:36 RPV

Sample Number: 7042907-63
Collector: NPA

Site: CR 110
Collect Date: 04/08/2017 10:28 am

Sample ID: RJMS-1FL-DW-CR 110
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 57.9 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:38 RPV

Sample Number: 7042907-64
Collector: NPA

Site: CR 112
Collect Date: 04/08/2017 10:29 am

Sample ID: RJMS-1FL-DW-CR 112
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 171 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:40 RPV

Sample Number: 7042907-65
Collector: NPA

Site: CR 112
Collect Date: 04/08/2017 10:30 am

Sample ID: RJMS-1FL-S-CR 112
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 97.5 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:42 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 7042907-66
Collector: NPA

Site: CR 111
Collect Date: 04/08/2017 10:31 am

Sample ID: RJMS-1FL-S-CR 111
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 42.6 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:44 RPV

Sample Number: 7042907-67
Collector: NPA

Site: O/S 111
Collect Date: 04/08/2017 10:32 am

Sample ID: RJMS-1FL-WC-O/S 111
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.83 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:45 RPV

Sample Number: 7042907-68
Collector: NPA

Site: Boys Rm 4
Collect Date: 04/08/2017 10:33 am

Sample ID: RJMS-1FL-S-Boys Rm 4
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.57 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:52 RPV

Sample Number: 7042907-69
Collector: NPA

Site: Boys Rm 5
Collect Date: 04/08/2017 10:34 am

Sample ID: RJMS-1FL-S-Boys Rm 5
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.42 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 19:58 RPV

Sample Number: 7042907-70
Collector: NPA

Site: Boys Rm 6
Collect Date: 04/08/2017 10:35 am

Sample ID: RJMS-1FL-S-Boys Rm 6
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.87 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:03 RPV

Sample Number: 7042907-71
Collector: NPA

Site: Girls Rm 4
Collect Date: 04/08/2017 10:36 am

Sample ID: RJMS-1FL-S-Girls Rm 4
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.56 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:05 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7042907-72
Collector: NPA

Site: Girls Rm 5
Collect Date: 04/08/2017 10:37 am

Sample ID: RJMS-1FL-S-Girls Rm 5
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.21 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:07 RPV

Sample Number: 7042907-73
Collector: NPA

Site: Girls Rm 6
Collect Date: 04/08/2017 10:38 am

Sample ID: RJMS-1FL-S-Girls Rm 6
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.04 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:09 RPV

Sample Number: 7042907-74
Collector: NPA

Site: CR 136W
Collect Date: 04/08/2017 10:39 am

Sample ID: RJMS-1FL-DW-CR 136W
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 10.4 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:15 RPV

Sample Number: 7042907-75
Collector: NPA

Site: CR 136W
Collect Date: 04/08/2017 10:40 am

Sample ID: RJMS-1FL-S-CR 136W
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.29 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:17 RPV

Sample Number: 7042907-76
Collector: NPA

Site: CR 137W
Collect Date: 04/08/2017 10:41 am

Sample ID: RJMS-1FL-DW-CR 137W
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.94 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:19 RPV

Sample Number: 7042907-77
Collector: NPA

Site: CR 137W
Collect Date: 04/08/2017 10:42 am

Sample ID: RJMS-1FL-S-CR 137W
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:21 RPV

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 7042907-78
Collector: NPA

Site: CR 138W
Collect Date: 04/08/2017 10:43 am

Sample ID: RJMS-1FL-DW-CR 138W
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.19 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:23 RPV

Sample Number: 7042907-79
Collector: NPA

Site: CR 138W
Collect Date: 04/08/2017 10:44 am

Sample ID: RJMS-1FL-S-CR 138W
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.47 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:25 RPV

Sample Number: 7042907-80
Collector:

Site: Laboratory Control Sample
Collect Date: 04/11/2017 12:00 am

Sample ID:
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.8 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:28 RPV

Sample Number: 7042907-81
Collector:

Site: Laboratory Control Sample Duplicate
Collect Date: 04/11/2017 12:00 am

Sample ID:
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.1 µg/L EPA 200.8 1.00 1 04/12/17 RPV 04/21/17 20:52 RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Alana Kopicz
Project Manager

Alana M. Kopicz

Report Generated On: 05/01/2017 2:45 pm 7042907
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



7042907
Alana Kopicz



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

IAI (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle		
	West Chester, PA 19380	Email:	nabraham@westchesterenv ironmental.com		95 E Main St, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
	Field Blank	04/08/17	09:25 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	RJMS---Field Blank
Flush	Conf. Rm Br	04/08/17	09:30 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-POE-Conf. Rm Br
First	Principals Office 1	04/08/17	09:31 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Principals Office 1
First	O/S Main Office	04/08/17	09:32 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-O/S Main Office
First	Lav @ Main Entry	04/08/17	09:33 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Lav @ Main Entry
First	Prep Rm	04/08/17	09:34 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Prep Rm
First	Hall o/s Computer Lab	04/08/17	09:35 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-WC-Hall o/s Computer Lab
First	Home EC Lab 1	04/08/17	09:35 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Home EC Lab 1
First	Home EC Lab 3	04/08/17	09:36 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Home EC Lab 3
First	Prep Rm-2	04/08/17	09:37 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Prep Rm-2

pkc2
↓

Relinquished by:

Date: 4/11/17

Time: 09:00

Received By:

Date: 4/11/17 Temp °C: 23.6

Time: 12:00 Acceptable Y/N

Relinquished by:

Date: 4/11/17 Temp °C: 13.6

Time: 15:20 Acceptable Y/N

Received in Lab By:

Date: 4/11/17 Temp °C:

Time: 15:20 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH A = Ascorbic H = HNO ₃ S = OH = O = Other NA = None Required	☐ Fax ☐ Email ☐ Other
All containers intact ☒ Y ☐ N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	☐ Return a copy of
Tests within holding times ☒ Y ☐ N			
40 ml. VOA vials free of headspace? ☒ Y ☐ N			



7042907
Alana Kopicz



SUBURBAN
TESTING LABS

TESTING LABS

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

(Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle		
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		95 E Main St, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Science Rm 1	04/08/17	09:38 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 1
First	Science Rm 2	04/08/17	09:39 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 2
First	Science Rm 3	04/08/17	09:40 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 3
First	Science Rm 4	04/08/17	09:41 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 4
First	Science Rm 5	04/08/17	09:42 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 5
First	Science Rm 6	04/08/17	09:43 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 6
First	Science Rm 7	04/08/17	09:44 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 7
First	Science Rm 8	04/08/17	09:45 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Science Rm 8
First	Girls Locker Rm	04/08/17	09:46 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Locker Rm
First	Boys Locker Rm	04/08/17	09:47 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Boys Locker Rm

pkc2
↓

Relinquished by:

[Signature]

Date: 4/11/17
Time: 09:00

Received By:

[Signature]

Date: 4/11/17 Temp °C: 23.6
Time: 2:00 Acceptable Y/N

Relinquished by:

[Signature]

Date: 4/11/17 Temp °C: 13.6
Time: 5:20 Acceptable Y/N

Received in Lab By:

[Signature]

Date: 4/11/17 Temp °C:
Time: 15:10 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance)		☐ Fax
All containers intact ☒ Y ☐ N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thiosulphate A = Ascorbic Acid H = HNO3 C = HCl H2SO4 NaOH S = OH = NA = None Required O = Other	☐ Email
Tests within holding times ☒ Y ☐ N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	☐ Other
40 ml. VOA vials free of headspace? ☒ Y ☐ N			☐ Return a copy of



7042907
Alana Kopicz



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle		
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		95 E Main St, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
First	Art Rm 1	04/08/17	09:48 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Art Rm 1
First	Art Rm 2	04/08/17	09:49 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Art Rm 2
First	Art Rm 3	04/08/17	09:50 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Art Rm 3
First	Art Rm 4	04/08/17	09:51 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Art Rm 4
First	Art Rm 5	04/08/17	09:52 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Art Rm 5
First	Art Rm 6	04/08/17	09:53 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Art Rm 6
First	Hall o/s Music Rm	04/08/17	09:54 AM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-Hall o/s Music Rm
First	Cafeteria 1	04/08/17	09:55 AM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-WC-Cafeteria 1
First	Kitchen 1	04/08/17	09:56 AM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Kitchen 1
First	Kitchen 2	04/08/17	09:57 AM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Kitchen 2

Relinquished by:

[Signature]
Received By:
Cathy Flynn

Date: 4/11/17
Time: 09:00
Date: 4/11/17 Temp °C: 23.6
Time: 12:00 Acceptable Y/N

Relinquished by:

Cathy Flynn


Date: 4/11/17 Temp °C: 13.8
Time: 15:20 Acceptable Y/N

Received in Lab By:

Ross McQueen

Date: 4/11/17 Temp °C:
Time: 15:20 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y/N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	☐ SWDA Reportin
Number of containers match ☒ Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH	☐ Fax ☐ Email
All containers intact ☒ Y/N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	☐ Other ☐ Return a copy of
Tests within holding times ☒ Y/N			
40 ml VOA vials free of headspace? ☒ Y/N			



TESTING LABS

Ch.

1037F MacArthur Road, Reading, PA 19605
610-375-TEST – Fax: 610-375-4090 – suburbantestinglabs.com

24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle
	West Chester, PA 19380				95 E Main St, Rockaway, NJ 07866
Contact Name:	Noel Abraham	Email:	nabraham@westchesterenv ironmental.com	Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type ^e	Preservative	Location Code
First	Kitchen 3	04/08/17	09:58 AM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-FP-Kitchen 3
First	Faculty Rm	04/08/17	09:59 AM	NPA	032	Pb EPA 200.8	1	PW	G	P	H	RJMS-2FL-FS-Faculty Rm
First	Nurse's Office	04/08/17	10:00 AM	NPA	033	Pb EPA 200.8	1	PW	G	P	H	RJMS-3FL-NS-Nurse's Office
First	CR 101	04/08/17	10:01 AM	NPA	034	Pb EPA 200.8	1	PW	G	P	H	RJMS-2FL-S -CR 101
First	CR 101	04/08/17	10:02 AM	NPA	035	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 101
First	CR 102	04/08/17	10:03 AM	NPA	036	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 102
First	Library	04/08/17	10:04 AM	NPA	037	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Library
First	Library	04/08/17	10:05 AM	NPA	038	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-Library
First	Girls Rm 1	04/08/17	10:06 AM	NPA	039	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Rm 1
First	Girls Rm 2	04/08/17	10:07 AM	NPA	040	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Rm 2

pH 2

Relinquished by:

Date: 4/11/17

Time: 09:00

Received By:

Date: 4/11/17 Temp °C: 23.6

Time/2:00 Acceptable Y / N

Relinquished by:

Date: 4/1/17 Temp °C: 13.6

Time: 5:10 Acceptable Y N

Received in Lab By:

Date: 11/11/17 Temp °C:

Time: Acceptable Y/N

Sample Conditions		Matrix Key		Bottle Type Key	Reporting options	
Submitted w/ COC	Y/N	NPW = Non-Potable Water		P = Plastic G = Glass O = Other	☐	SWDA Reportin
Number of containers match	Y/N	Solid = Raw Sludge, Dewatered Sludge soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample		Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH	☐	Fax
All containers intact	Y/N	Sample Type Key	SWDA Sample Type	A = Ascorbic H = HNO ₃ S = OH = O = Other	☐	Email
Tests within holding times	Y/N	G = Grab 8 HC = 8 Hour Composite	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	NA = None Required	☐	Other
40 ml. YOA vials free of headspace?	Y/N	24 HC = 24 Hour Composite			☐	Return a copy of



7042907
Alana Kopicz



TESTING LABS

Chain of

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle		
	West Chester, PA 19380	Email:	nabraham@westchesterenviro		95 E Main St, Rockaway, NJ 07866		
Contact Name:	Noel Abraham		ironmental.com	Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
First	Girls Rm 3	04/08/17	10:08 AM	NPA	041	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Rm 3
First	O/S 118	04/08/17	10:09 AM	NPA	042	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-WC-O/S 118
First	Boys Rm 2	04/08/17	10:10 AM	NPA	043	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Boys Rm 2
First	Boys Rm 3	04/08/17	10:11 AM	NPA	044	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Boys Rm 3
First	CR 105	04/08/17	10:12 AM	NPA	045	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 105
First	CR 105	04/08/17	10:13 AM	NPA	046	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 105
First	CR 117	04/08/17	10:14 AM	NPA	047	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 117
First	CR 117	04/08/17	10:14 AM	NPA	048	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 117
First	CR 106	04/08/17	10:15 AM	NPA	049	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 106
First	CR 106	04/08/17	10:16 AM	NPA	050	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 106

Relinquished by:

[Signature]

Received By:

[Signature]

Relinquished by:

[Signature]

Received in Lab By:

[Signature]

Date: 4/11/17

Time: 09:00

Date: 4/11/17 Temp °C: 23.6

Time: 12:00 Acceptable Y/N

Date: 4/11/17 Temp °C: 13.6

Time: 15:20 Acceptable Y/N

Date: 4/11/17 Temp °C:

Time: 15:20 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass	☐ Fax
All containers intact ☒ Y ☐ N	PW = Potable Water (not for SWDA compliance)	O = Other	☐ Email
Tests within holding times ☒ Y ☐ N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	☐ Other
40 ml VOA vials free of headspace? ☒ Y ☐ N	Sample Type Key D = Distribution G = Grab HC = 8 Hour Composite 24 HC = 24 Hour Composite	H = Sodium Thiosulphate A = Ascorbic Acid H = HNO3 C = HCl H2SO4 NaOH OH = NA = None Required	☐ Return a copy of
	SWDA Sample Type E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		



7042907
Alana Kopicz



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

24hr 48hr 72hr Other

Client Name: Westchester Environmental LLC.		Project Name: Rockaway Borough SD	
Address: 307 N. Walnut Street	Phone: 610-883-3839	Address: Thomas Jefferson Middle	
West Chester, PA 19380	Email: nabraham@westchesterenviromental.com	95 E Main St, Rockaway, NJ 07866	
Contact Name: Noel Abraham		Payment / P.O. Info:	

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
First	CR 116	04/08/17	10:16 AM	NPA	051	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 116
First	CR 116	04/08/17	10:17 AM	NPA	052	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 116
First	CR 107	04/08/17	10:18 AM	NPA	053	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 107
First	CR 107	04/08/17	10:19 AM	NPA	054	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 107
First	CR 108	04/08/17	10:20 AM	NPA	055	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 108
First	CR 108	04/08/17	10:21 AM	NPA	056	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 108
First	CR 115	04/08/17	10:22 AM	NPA	057	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 115
First	CR 114	04/08/17	10:23 AM	NPA	058	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 114
First	CR 114	04/08/17	10:24 AM	NPA	059	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW -CR 114
First	CR 109	04/08/17	10:24 AM	NPA	060	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 109

Relinquished by:

[Signature]

Date: **4/11/17**
Time: **09:05**

Received By:

[Signature]

Date: **4/11/17** Temp °C: **23.6**
Time: **12:00** Acceptable ☒ Y / N

Relinquished by:

[Signature]

Date: **4/11/17** Temp °C: **13.6**
Time: **15:20** Acceptable ☒ Y / N

Received in Lab By:

[Signature]

Date: **4/14/17** Temp °C:
Time: **15:20** Acceptable ☒ Y / N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y / N	NPW = Non-Potable Water	P = Plastic	☐ SWDA Reportin
Number of containers match ☒ Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance)	G = Glass	☐ Fax
All containers intact ☒ Y / N	SWDA = Safe Drinking Water Act Potable Sample	O = Other	☐ Email
Tests within holding times ☒ Y / N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH A = Ascorbic H = HNO ₃ S = OH = O = Other NA = None Required	☐ Other
40 ml. VOA vials free of headspace? ☒ Y / N	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		☐ Return a copy of



7042907
Alana Kopicz



Chain of Custody Record

TAT (Check One) ☐ Standard ☒ 24hr ☐ 48hr ☐ 72hr ☐ Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle		
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		95 E Main St, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
First	CR 113	04/08/17	10:26 AM	NPA	061	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 113
First	CR 110	04/08/17	10:27 AM	NPA	062	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 110
First	CR 110	04/08/17	10:28 AM	NPA	063	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 110
First	CR 112	04/08/17	10:29 AM	NPA	064	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 112
First	CR 112	04/08/17	10:30 AM	NPA	065	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 112
First	CR 111	04/08/17	10:31 AM	NPA	066	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 111
First	O/S 111	04/08/17	10:32 AM	NPA	067	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-WC-O/S 111
First	Boys Rm 4	04/08/17	10:33 AM	NPA	068	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Boys Rm 4
First	Boys Rm 5	04/08/17	10:34 AM	NPA	069	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Boys Rm 5
First	Boys Rm 6	04/08/17	10:35 AM	NPA	070	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Boys Rm 6

prtc2
↓

Relinquished by:

[Signature]

Received By:

[Signature]

Relinquished by:

[Signature]

Received in Lab By:

[Signature]

Date: 4/11/17

Time: 08:00

Date: 4/11/17 Temp °C: 23.6

Time: 12:00 Acceptable Y/N

Date: 4/11/17 Temp °C: 13.6

Time: 15:20 Acceptable Y/N

Date: 4/11/17

Time: 15:20 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y/N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	☐ SWDA Reportin
Number of containers match ☒ Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance)	Preservative Key	☐ Fax
All containers intact ☒ Y/N	SWDA = Safe Drinking Water Act Potable Sample	H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH	☐ Email
Tests within holding times ☒ Y/N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	☐ Other
40 ml. VOA vials free of headspace? ☒ Y/N		A = Ascorbic H = HNO ₃ S = OH = O = Other NA = None Required	☐ Return a copy of



7042907
Alana Kopicz



SUBURBAN
TESTING LABS

TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

1 hr (check one) ☐ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rockaway Borough SD		
Address:	307 N. Walnut Street	Phone:	610-883-3839	Address:	Thomas Jefferson Middle		
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		95 E Main St, Rockaway, NJ 07866		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
First	Girls Rm 4	04/08/17	10:36 AM	NPA	071	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Rm 4
First	Girls Rm 5	04/08/17	10:37 AM	NPA	072	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Rm 5
First	Girls Rm 6	04/08/17	10:38 AM	NPA	073	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -Girls Rm 6
First	CR 136W	04/08/17	10:39 AM	NPA	074	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 136W
First	CR 136W	04/08/17	10:40 AM	NPA	075	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 136W
First	CR 137W	04/08/17	10:41 AM	NPA	076	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 137W
First	CR 137W	04/08/17	10:42 AM	NPA	077	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 137W
First	CR 138W	04/08/17	10:43 AM	NPA	078	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 138W
First	CR 138W	04/08/17	10:44 AM	NPA	079	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S -CR 138W

Relinquished by:

[Signature]

Received By:

[Signature]

Relinquished by:

[Signature] (9)

Received in Lab By:

[Signature]

Date: 4/11/17 *PHV CAF 4/11/17*
Time: 09:00
Date: 4/11/17 Temp °C: 23.6
Time: 12:00 Acceptable ☒ N
Date: 4/11/17 Temp °C: 13.6
Time: 15:20 Acceptable ☒ N
Date: 4/11/17 Temp °C:
Time: 15:20 Acceptable ☒ N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC ☒ Y ☐ N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	☐ SWDA Reportin
Number of containers match ☒ Y ☐ N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH A = Ascorbic H = HNO ₃ S = OH = O = Other NA = None Required	☐ Fax ☐ Email
All containers intact ☒ Y ☐ N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		☐ Other ☐ Return a copy of